

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-23-001060

**Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.**

The French PROCES VERBAL is valid for 5 years starting on April 26th, 2023

Applicant	BRAND MANAGEMENT GROUP LLC 1605 Main St., Suite 300 SARASOTA, FL 34236 USA
Sample reference	HP RECYCLED REMOVABLE ADHESIVE FABRIC (LATEX/SOLVENT)
Brief description provided by the applicant	The product is made of polyethylene and an adhesive.
Mass per unit area provided by the applicant	186 g/m ²
Thickness provided by the applicant	0,15 mm
Colour	White
End-use condition	Digital print receptive self-adhesive wall covering

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-501 (1995)** - Reaction to fire tests Radiation test used for rigid materials, or for materials on rigid substrates (flooring and finishes) of all thicknesses, and for flexible materials thicker than 5 mm

Classification obtained in the official Procès Verbal:

M1

Valid only self-adhesive on plasterboard

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-23-001060-EPI from May 04th, 2023.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on May 04th, 2023