


Cobb County Fire & Emergency Services

<p>Fire Marshal's Office</p>  <p>Plan Review</p>	<p>Kiosk Checklist¹ – 2012 Life Safety Code</p> <p>Job Name: _____</p> <p>Address: _____ Kiosk#: _____</p> <p>City: _____ Zip: _____</p> <p>Responsible Party: _____ Phone: _____</p> <p>Email: _____</p> <p>GENERAL BUILDING INFORMATION:</p> <p>Area of Kiosk: _____ Area of Adjacent Kiosks within 20 feet : _____</p> <p>Occupancy Type: _____ Occupant Load _____</p>
--	---

✓ = Pass, **X** = Fail, **NA** = Not applicable **Status**

DRAWING SUBMITTAL REQUIREMENTS

- | | |
|--|--|
| 1) Correct job name, address, and kiosk/suite number on the drawings | |
| 2) Key Plan showing location of kiosk on overall mall plan | |
| 3) Show all adjacent kiosks within 20 ft of the proposed kiosk (see sample kiosk drawing) | |
| 4) Provide dimensions of the kiosk on the drawings | |
| 5) Indicate distance from kiosk to obstructions (i.e. other kiosk, railings or tenant store front) | |


SIZE AND LOCATION OF KIOSK

- | | |
|--|--|
| 6) Maximum size of a kiosk or group of kiosks shall not exceed 300 sq ft – LSC 36.4.4.8(4) | |
| 7) Provide a minimum 10 ft clearance between the kiosk and other obstructions such as a tenant space – LSC 36.4.4.2.2(1) | |
| 8) Must confirm a minimum 20 ft overall pedestrian clearance is provided where the kiosk is located (10 feet minimum on each side) – LSC 36.4.4.2.2(1) | |
| 9) Provide a 20 ft separation for 300 sq ft kiosk or groups of kiosks having a total sq ft of 300 sq ft from other kiosks or groups of kiosk – LSC 36.4.4.8(3) | |
| 10) | |

KIOSK BUILDING MATERIALS

- | | |
|---|--|
| 11) Kiosk must be constructed of noncombustible material – LSC 36.4.4.8 | |
| 12) Must provide documentation for combustible kiosk for each type of combustible material used (i.e. fire-retardant-treated wood, flame spread for metal composite material, textiles) LSC 36.4.4.8(1) | |

EXAMPLE KIOSK DRAWING



¹ The above is not an all-inclusive list, all applicable fire and life safety provisions must be met.

Notes: _____

Reviewer: _____ Date: _____