



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Feb 5, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 4, 2019  
Location of overflow: 628 RIVER BEND CIR SW SMYRNA 30082  
This overflow resulted from: STRUCTURAL  
Resulting in a wastewater discharge into: Mill Creek #2  
The volume of the overflow was estimated at: 270 Gallons  
The Water System was notified at: Feb 4, 2019, 12:30 PM  
The overflow was stopped at: Feb 4, 2019, 2:45 PM

Corrective action taken to reduce effects of the overflow include the following:

Cut out and replaced broken section of pipe.

Field Observation:

Upon arrival, found stream crossing pipe was leaking in creek. Light grey area discharging from broken area of pipe into waterway.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**