



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Mar 6, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 6, 2019
Location of overflow: 775 SMYRNA POWDER SPRINGS RD, Marietta, 30060
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: Tributary to Mill creek.
The volume of the overflow was estimated at: 90 Gallons
The Water System was notified at: Mar 6, 2019, 10:33 AM
The overflow was stopped at: Mar 6, 2019, 11:10 AM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped the blockage, cleaned and spread lime around spill area.

Field Observation:

Upon arrival, grey water was running from an area of 2 ft x 30 ft from the manhole to the creek area.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release