



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Mar 27, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 26, 2019
Location of overflow: 1741 OLIVE SPRINGS RD, Marietta, GA 30060
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: Tributary to Nickajack Creek
The volume of the overflow was estimated at: 110 Gallons
The Water System was notified at: Mar 26, 2019, 12:05 PM
The overflow was stopped at: Mar 26, 2019, 1:00 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstop blockage, clean and spread lime around spill area. Video inspect main line for follow up.

Field Observation:

Upon arrival, found manhole #202-0047 spilling over with lid on, making a 2' x 10' long trail of grey water running and discharging in the creek area.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release