



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Apr 8, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: April 6, 2019
Location of overflow: 4752 NETHERSTONE CT Marietta, GA 30066
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: Tributary to Trickum Creek
The volume of the overflow was estimated at: 190 Gallons
The Water System was notified at: Apr 6, 2019, 8:30 PM
The overflow was stopped at: Apr 6, 2019, 10:05 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped the blockage with the jet machine. Cleaned and spread lime around spill area.

Field Observation:

Upon arrival, grey water was spilling out of manhole # 332-E011. A grey stain flowed into the creek in an area of 10 ft x 10 ft.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release