



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Apr 22, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: April 19, 2019
Location of overflow: 4395 WOODLAND BROOK DR SE, Atlanta, GA 30339
This overflow resulted from: STRUCTURAL
Resulting in a wastewater discharge into: Tributary to Gilmore Creek
The volume of the overflow was estimated at: 2700 Gallons
The Water System was notified at: Apr 19, 2019, 7:15 PM
The overflow was stopped at: Apr 19, 2019, 9:30 PM

Corrective action taken to reduce effects of the overflow include the following:

Dug up 8 inch line hit by contractor, removed jet head from line and replaced it with 8 inch pvc.

Field Observation:

Upon arrival, found manhole spilling into creek in an area of 3 ft x 8 ft , leaving grey stains on the ground.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release