



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Jun 12, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 11, 2019  
Location of overflow: 1515 N COBB PKWY, MARIETTA, GA 30066  
This overflow resulted from: GRAVEL  
Resulting in a wastewater discharge into: Noonday Creek Tributary #4  
The volume of the overflow was estimated at: 290 Gallons  
The Water System was notified at: Jun 11, 2019, 7:35 PM  
The overflow was stopped at: Jun 11, 2019, 9:30 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped the blockage with jet machine, cleaned and spread lime around spill area.

Field Observation:

Clear liquid spilled from the manhole with lid in place. Light grey stains ran directly into creek. The affected area was about 10 ft by 20 ft .

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**