



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Jun 28, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 28, 2019  
Location of overflow: 2091 REVERIE RDG, MARIETTA, GA 30068  
This overflow resulted from: DEBRIS  
Resulting in a wastewater discharge into: Tributary to Willeo Creek  
The volume of the overflow was estimated at: 120 Gallons  
The Water System was notified at: Jun 28, 2019, 8:56 AM  
The overflow was stopped at: Jun 28, 2019, 9:55 AM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to unstop the main. Video inspected the sewer line to find the cause of the problem. Cleaned spill area.

Field Observation:

Upon arrival, found the street was wet at the manhole and sewage spilling through the lid. Sewage ran towards the storm drain on the side of the street. No odor was detected, and the creek was running clear.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**