



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Jul 2, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: July 1, 2019
Location of overflow: 1187 SMITHWELL PT, KENNESAW, GA 30152
This overflow resulted from: GRAVEL
Resulting in a wastewater discharge into: Tributary to Noonday Creek
The volume of the overflow was estimated at: 130 Gallons
The Water System was notified at: Jul 1, 2019, 9:15 AM
The overflow was stopped at: Jul 1, 2019, 10:20 AM

Corrective action taken to reduce effects of the overflow include the following:
Unstopped overflowing manhole with the jet machine. Cleaned and limed spill area.

Field Observation:

Upon arrival, the crew observed grey water discharging from manhole # 306-0106 into a drainage ditch which flows into Noonday Creek. Light grey stains with debris were seen in an area of 10 ft x 30 ft.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release