



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Jul 11, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: July 10, 2019  
Location of overflow: 812 DANIELL DR, SMYRNA, GA 30080  
This overflow resulted from: SOLIDS  
Resulting in a wastewater discharge into: Theater Branch  
The volume of the overflow was estimated at: 150 Gallons  
The Water System was notified at: Jul 10, 2019, 1:05 PM  
The overflow was stopped at: Jul 10, 2019, 2:05 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to unstop the blockage. Cleaned & limed spill area. Follow up inspection ticket was made.

Field Observation:

Upon arrival, the crew could smell a sewage odor. The manhole was spilling with the lid in place. Water in the creek was grey.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**