



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Sep 23, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: September 22, 2019
Location of overflow: 4377 DUNMORE RD NE, MARIETTA, GA 30068
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: Tributary to Bishop Creek
The volume of the overflow was estimated at: 270 Gallons
The Water System was notified at: Sep 22, 2019, 1:35 PM
The overflow was stopped at: Sep 22, 2019, 3:50 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped the blockage with the jet machine, cleaned and limed spill area.

Field Observation:

Upon arrival, the crew found manhole # 191-I156 spilling with lid in place. The spill flowed into the creek and left gray stain in an area of 10' x 10'.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release