



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Oct 28, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: October 24, 2019  
Location of overflow: 2080 FAVOR RD , Marietta, GA 30060  
This overflow resulted from: GREASE  
Resulting in a wastewater discharge into: Tributary to Nickajack Creek  
The volume of the overflow was estimated at: 290 Gallons  
The Water System was notified at: Oct 24, 2019, 4:35 PM  
The overflow was stopped at: Oct 24, 2019, 7:00 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped the blockage with the jet machine and washed down road.

Field Observation:

Clear liquids ran from the manhole with the lid in place. Sewage ran from the manhole across the road running directly into a storm drain.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**