



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Dec 11, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: December 10, 2019  
Location of overflow: 131 CHERRY HILL DR SE INFLOW, Marietta, GA 30067  
This overflow resulted from: Inflow  
Resulting in a wastewater discharge into: Tributary to Sope Creek  
The volume of the overflow was estimated at: 360 Gallons  
The Water System was notified at: Dec 10, 2019, 11:00 AM  
The overflow was stopped at: Dec 10, 2019, 12:00 PM

Corrective action taken to reduce effects of the overflow include the following:

Flushed sewer main. Follow up for video inspection.

Field Observation:

Upon arrival, the crew observed slightly grey water in a 3 ft x 3 ft area, with little odor.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**