



## COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,  
Director

### Customer Services Facility

660 South Cobb Drive  
Marietta, GA 30060-3105  
Phone: (770) 419-6200

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Dec 16, 2019

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: December 14, 2019  
Location of overflow: 615 WILLOW RIDGE DR, Marietta, GA 30068  
This overflow resulted from: GREASE  
Resulting in a wastewater discharge into: Campground Creek  
The volume of the overflow was estimated at: 260 Gallons  
The Water System was notified at: Dec 14, 2019, 8:30 AM  
The overflow was stopped at: Dec 14, 2019, 10:40 AM

Corrective action taken to reduce effects of the overflow include the following:

Unstop blockage with jet machine, clean and spread lime around spill area.

Field Observation:

Upon arrival, found manhole #104- X181 spilling into a nearby the creek, leaving a light grey stain 10 ft X 20 ft around manhole.

For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

**For Immediate Release**