



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.,
Director

Customer Services Facility

660 South Cobb Drive
Marietta, GA 30060-3105
Phone: (770) 419-6200

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Jan 2, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: December 31, 2019
Location of overflow: 1453 BROOKLINE CT, Mableton, GA 30126
This overflow resulted from: ROOTS
Resulting in a wastewater discharge into: Tributary to Nickajack Creek
The volume of the overflow was estimated at: 310 Gallons
The Water System was notified at: Dec 31, 2019, 11:13 AM
The overflow was stopped at: Dec 31, 2019, 12:05 PM
Corrective action taken to reduce effects of the overflow include the following:
Unstopped the blockage with the jet machine. Cleaned and spread lime around spill area.
Field Observation:
Upon arrival, the crew observed a grey stain around the manhole in a 3 ft x 10 ft area.
For more information on this notification or the local Cobb County Water, System Maintenance Program, contact our System Maintenance Division, Monday - Friday. 8am to 5pm at 770/419-6351.

###

For Immediate Release