



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Feb 11, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 6, 2020
Location of overflow: 3251 BARNWELL TRCE , POWDER SPRINGS , GA , 30127
This overflow resulted from: INFLOW
Resulting in a wastewater discharge into: NOSES CREEK
The volume of the overflow was estimated at: 36,160 Gallons
The Water System was notified at: Feb 6, 2020, 4:56 PM
The overflow was stopped at: Feb 7, 2020, 8:00 AM

Corrective action taken to reduce effects of the overflow include the following:

Wait for flood waters to recede.

Field Observation:

Located manhole, not on maps, down stream of manhole #248-9034 and manhole # 248-H000 overflowing with the lids in place. The area was flooded around the manholes. On 2/7/20 returned to site and did not find evidence of the manholes overflowing. The flood waters scoured the area of any debris from the overflow.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release