



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Feb 14, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 13, 2020
Location of overflow: 3973 TOWBRIDGE CT SW, SMYRNA, GA 30082
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: CONCORD CREEK
The volume of the overflow was estimated at: 260 Gallons
The Water System was notified at: Feb 13, 2020, 2:50 PM
The overflow was stopped at: Feb 13, 2020, 3:20 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to unstop blockage from mainline. Cleaned spill area and spread lime.

Field Observation:

Upon arrival, found manhole discharging sewage and running into nearby creek. Sewage left a spill area of 2'X10'.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release