



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Feb 21, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 20, 2020
Location of overflow: 2692 HOLMES MILL PL SW, MARIETTA, GA, 30064
This overflow resulted from: INFLOW
Resulting in a wastewater discharge into: TRIBUTARY TO NOSES CREEK
The volume of the overflow was estimated at: 75,350 Gallons
The Water System was notified at: Feb 20, 2020, 4:54 PM
The overflow was stopped at: Feb 21, 2020, 4:19 AM

Corrective action taken to reduce effects of the overflow include the following:

Crew stayed on site and waited for inflow to stop. Cleaned and limed spill area.

Field Observation:

Upon arrival, found sewage escaping from clean-outs on property. Sewage left a spill area of 5'X20' leading to creek.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release