



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Mar 9, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 6, 2020
Location of overflow: 137 JOHNSON FERRY RD, MARIETTA, GA 30067
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: Tributary to Chattahoochee River
The volume of the overflow was estimated at: 60 Gallons
The Water System was notified at: Mar 6, 2020, 2:46 PM
The overflow was stopped at: Mar 6, 2020, 3:15 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to unstop the sewer main and rinse down the road. Follow up work is scheduled.

Field Observation:

Upon arrival, the crew observed a little water on the road behind the 137 Johnson Ferry Rd. Grey water was spilling from MH#105-E178B, and running 30 ft away into a storm drain, eventually making a path Tributary to Chattahoochee River. No odor detected and the manhole lid was in place.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

For Immediate Release