



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release Information on Sewer Overflow

Cobb County, GA - Mar 20, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 19, 2020  
Location of overflow: 21 SIMPSON DR , KENNESAW, GA 30144  
This overflow resulted from: SOLIDS  
Resulting in a wastewater discharge into: TRIBUTARY TO NOONDAY CREEK TRIBUTARY #1

The volume of the overflow was estimated at: 260 Gallons

The Water System was notified at: Mar 19, 2020, 8:50 PM

The overflow was stopped at: Mar 19, 2020, 11:00 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped blockage with the jet machine. Washed down road and used potpourri around area.

Field Observation:

Upon arrival, manhole was spilling on the side of the road. Sewage ran into the curb and down into the storm drain. Sewage left a grayish liquid about 18-24 inches wide.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**