



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Mar 30, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 28, 2020
Location of overflow: 2928 GEORGE BUSBEE PKWY, KENNESAW, GA 30144
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: NOONDAY CREEK
The volume of the overflow was estimated at: 100 Gallons
The Water System was notified at: Mar 28, 2020, 4:25 PM
The overflow was stopped at: Mar 28, 2020, 5:15 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to flush sewer line. Video inspected sewer main. Washed down the curb. No further work needed.

Field Observation:

Upon arrival there was no odor or visible solids. The manhole was seeping grey water at the lid. The liquid made a path to the curb a foot away, and followed the curb to the storm drain approximately 170 ft away.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release