



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Apr 1, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 31, 2020
Location of overflow: 812 DANIELL DR
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: THEATER BRANCH
The volume of the overflow was estimated at: 410 Gallons
The Water System was notified at: Mar 31, 2020, 3:32 PM
The overflow was stopped at: Mar 31, 2020, 4:30 PM

Corrective action taken to reduce effects of the overflow include the following:

Used Jet machine to unstop the line and washed down the street. Further inspection is needed.

Field Observation:

When the crew arrived on-site, manhole # 202-C005 was barely seeping liquid out of the lid. A small amount of sewage puddled in street and then trickled into the storm drain. No odor were present or solids were visible.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release