



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - May 11, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: May 10, 2020
Location of overflow: 1034 PEACE DR, KENNESAW, GA 30152
This overflow resulted from: STRUCTURAL
Resulting in a wastewater discharge into: TRIBUTARY TO ALLATOONA CREEK
The volume of the overflow was estimated at: 290 Gallons
The Water System was notified at: May 10, 2020, 3:56 PM
The overflow was stopped at: May 10, 2020, 6:23 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped blockage with jet machine and cleaned affected area.

Field Observation:

Upon arrival, found manhole 522-H010 overflowing into the creek. Sewage left a 5'X10' grey area of solids from manhole to stream.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release