



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release

## Information on Sewer Overflow

Cobb County, GA - May 26, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: May 25, 2020  
Location of overflow: 2920 GEORGE BUSBEE PKWY, KENNESAW, GA 30144  
This overflow resulted from: RAGS  
Resulting in a wastewater discharge into: NOONDAY CREEK  
The volume of the overflow was estimated at: 230 Gallons  
The Water System was notified at: May 25, 2020, 5:24 PM  
The overflow was stopped at: May 25, 2020, 7:20 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to clear blockage from main line. Servpro came and cleaned spill area.

Field Observation:

Upon arrival, found clean-out beside the strip mall discharging sewage. Sewage left a 5' area around the clean-out, and a 3' X 145' trail leading to storm drain.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**