



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Jun 22, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: June 19, 2020
Location of overflow: 5139 FAWN TRL, MABLETON, GA 30126
This overflow resulted from: SOLIDS
Resulting in a wastewater discharge into: TRIBUTARY TO NICKAJACK CREEK
The volume of the overflow was estimated at: 500 Gallons
The Water System was notified at: Jun 19, 2020, 2:46 PM
The overflow was stopped at: Jun 19, 2020, 4:10 PM

Corrective action taken to reduce effects of the overflow include the following:
Used jet machine to clear blockage from main line. Spread lime and enzymes over affected area.

Field Observation:

Sewage entered a storm drain which discharges into an open ditch. Sewage left a 3' x 30' gray stained area, no solids found on the ground.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release