



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jul 6, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: July 4, 2020
Location of overflow: 3850 LOCH HIGHLAND PKWY, ROSWELL, GA 30075
This overflow resulted from: GRAVEL
Resulting in a wastewater discharge into: LOCH HIGHLAND #1 LAKE, TRIBUTARY TO SWEAT MOUNTAIN CREEK
The volume of the overflow was estimated at: 5,220 Gallons
The Water System was notified at: Jul 4, 2020, 1:48 PM
The overflow was stopped at: Jul 4, 2020, 5:30 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped blockage with jet machine, and spread lime around spill area.

Field Observation:

Upon arrival, found liquid discharging from clean-out, leaving light gray stains on ground. Sewage left a spill area of 5' X 75' leading from the yard and into the lake.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release