



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jul 15, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: July 14, 2020
Location of overflow: 4169 NANCE RD, KENNESAW, GA 30144
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: TRIBUTARY TO BUTLER CREEK
The volume of the overflow was estimated at: 100 Gallons
The Water System was notified at: Jul 14, 2020, 10:50 AM
The overflow was stopped at: Jul 14, 2020, 11:40 AM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped blockage with jet machine and sprayed enzymes on spill area.

Field Observation:

Upon arrival, found sewage discharging from manhole with lid in place. Sewage left a light gray 10' x 30' area, with no solids or debris in nearby waterway.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release