



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release Information on Sewer Overflow

Cobb County, GA - Jul 15, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: July 14, 2020
Location of overflow: 2800 PACES FERRY RD, ATLANTA, GA 30339
This overflow resulted from: SOLIDS
Resulting in a wastewater discharge into: VININGS BRANCH
The volume of the overflow was estimated at: 430 Gallons
The Water System was notified at: Jul 14, 2020, 3:55 PM
The overflow was stopped at: Jul 14, 2020, 7:30 PM

Corrective action taken to reduce effects of the overflow include the following:
Used jet machine to clear blockage from main line. Cleaned and limed spill area.

Field Observation:

Upon arrival, found manhole in southwest corner of complex near Lonesome Pine Lane discharging sewage. Sewage was spilling from manhole with the lid in place, leaving a 2'-3' area around manhole and then entered waterway.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release