



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Sep 14, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: September 13, 2020  
Location of overflow: 5695 HARBORMIST DR., POWDER SPRINGS, GA 30127  
This overflow resulted from: RAGS  
Resulting in a wastewater discharge into: MILL CREEK #1  
The volume of the overflow was estimated at: 540 Gallons  
The Water System was notified at: Sep 13, 2020, 10:00 AM  
The overflow was stopped at: Sep 13, 2020, 2:30 PM

Corrective action taken to reduce effects of the overflow include the following:

Use jet machine to clear blockage in main line. Cleaned the spill area.

### Field Observation:

Upon arrival, found manhole discharging sewage with lid in place. The manhole was found in woods. The sewage left a 8' x 20' spill area leading from manhole to waterway. No solids found in creek.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**