



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Sep 14, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: September 13, 2020
Location of overflow: 2385 JUNE SPRINGS DR, MARIETTA, GA 30008
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: TRIBUTARY TO OLLEY CREEK
The volume of the overflow was estimated at: 250 Gallons
The Water System was notified at: Sep 13, 2020, 9:38 AM
The overflow was stopped at: Sep 13, 2020, 11:45 AM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to clear blockage from main line. Cleaned the spill area.

Field Observation:

Upon arrival, found manhole discharging sewage with lid in place. Manhole was located in the street and only liquids were visible; no solids were found. The creek was clear with no discoloration; only odor was observed.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release