



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Oct 12, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: October 12, 2020  
Location of overflow: 1340 MARIETTA COUNTRY CLUB DR., KENNESAW, GA 30152  
This overflow resulted from: GREASE  
Resulting in a wastewater discharge into: NOONDAY CREEK  
The volume of the overflow was estimated at: 400 Gallons  
The Water System was notified at: Oct 12, 2020, 10:04 AM  
The overflow was stopped at: Oct 12, 2020, 11:10 AM

Corrective action taken to reduce effects of the overflow include the following:  
Used jet machine to clear blockage. Cleaned affected area with enzymes and lime.

### Field Observation:

Upon arrival, found manhole discharging sewage with lid in place. Sewage left a 20' x 20' light gray area with light debris. No solids visible, only liquid.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**