



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Oct 20, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: October 20, 2020  
Location of overflow: 1445 BROOKCLIFF PL, MARIETTA, GA 30062  
This overflow resulted from: GRAVEL  
Resulting in a wastewater discharge into: TRIBUTARY TO SEWELL MILL CREEK  
The volume of the overflow was estimated at: 40 Gallons  
The Water System was notified at: Oct 20, 2020, 8:32 AM  
The overflow was stopped at: Oct 20, 2020, 8:50 AM

Corrective action taken to reduce effects of the overflow include the following:

Used Jet Machine to clear blockage from main line. Cleaned spilled area and applied lime.

### Field Observation:

Upon arrival, crew observed sewage coming out of manhole with the lid in place. Sewage left a 2' x 6' trail leading to creek. 60' of the creek had gray tint from sewage.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**