



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions:

Business Services
Customer Services
Engineering & Records
Environmental Compliance
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Nov 17, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: November 16, 2020
Location of overflow: 275 ROCKIN HILL DR SW, MARIETTA, GA 30060
This overflow resulted from: STRUCTURAL
Resulting in a wastewater discharge into: TRIBUTARY TO FAVOR CREEK
The volume of the overflow was estimated at: 1740 Gallons
The Water System was notified at: Nov 16, 2020, 10:17 AM
The overflow was stopped at: Nov 16, 2020, 11:45 AM

Corrective action taken to reduce effects of the overflow include the following:

Crews made an emergency temporary repair on sewer main to stop leak.

Field Observation:

Upon arrival, crews found the creek crossing was broken in half by a tree. Sewage was running straight out of pipe and directly into creek.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release