



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

### Divisions:

Business Services  
Customer Services  
Engineering & Records  
Environmental Compliance  
Stormwater Management  
System Maintenance  
Water Protection

# Press Release

## Information on Sewer Overflow

Cobb County, GA - Nov 17, 2020

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: November 16, 2020  
Location of overflow: 815 SOUTH COBB DR, MARIETTA, GA 30060  
This overflow resulted from: STRUCTURAL  
Resulting in a wastewater discharge into: OLLEY CREEK  
The volume of the overflow was estimated at: 210 Gallons  
The Water System was notified at: Nov 16, 2020, 3:15 PM  
The overflow was stopped at: Nov 16, 2020, 5:00 PM

Corrective action taken to reduce effects of the overflow include the following:

Crew made repair on broken sewer main to stop the leak.

### Field Observation:

Upon arrival, crew found sewage leaking into creek from broken pipe. Sewage left a 5' X 5' gray spill area.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**