



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Jan 26, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: January 25, 2021
Location of overflow: 1270 COLONY PL NE, MARIETTA, GA 30068
This overflow resulted from: DEBRIS
Resulting in a wastewater discharge into: TRIBUTARY TO TIMBER RIDGE BRANCH
The volume of the overflow was estimated at: 7020 Gallons
The Water System was notified at: Jan 25, 2021, 2:30 PM
The overflow was stopped at: Jan 26, 2021, 12:30 AM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to clear blockage from mainline. Used camera to locate problem, and repaired tap. Cleaned and spread lime around spill area.

Field Observation:

Upon arrival, crew found 4 inch tap broken and spilling sewage into waterway.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release