



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
Accounting  
Communications & Education  
Customer Service  
Engineering & Records  
Stormwater Management  
System Maintenance  
Water Protection

## Press Release

## Information on Sewer Overflow

Cobb County, GA - Feb 25, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 24, 2021  
Location of overflow: 5258 MAPLE VALLEY RD SW, MABLETON, GA 30126  
This overflow resulted from: GREASE  
Resulting in a wastewater discharge into: TRIBUTARY TO NICKAJACK CREEK  
The volume of the overflow was estimated at: 190 Gallons  
The Water System was notified at: Feb 24, 2021, 6:50 PM  
The overflow was stopped at: Feb 24, 2021, 8:25 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to clear blockage. Cleaned affected area and spread lime to control odor.

Field Observation:

Upon arrival, crew found manhole #208-C084 spilling with lid in place. Sewage left a 10' x 25' gray stain area around the manhole leading to the waterway.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**