



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Mar 1, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: February 27, 2021
Location of overflow: 570 CHURCH RD SE, SMYRNA, GA 30082
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: TRIBUTARY TO SMYRNA BRANCH
The volume of the overflow was estimated at: 240 Gallons
The Water System was notified at: Feb 27, 2021, 11:05 AM
The overflow was stopped at: Feb 27, 2021, 1:05 PM
Corrective action taken to reduce effects of the overflow include the following:
Used jet machine to clear blockage from main line. Cleaned the affected area with water.
Field Observation:
Upon arrival, crew found manhole #205-D013 spilling with lid in place. Sewage overflowed from manhole and entered into the waterway.
For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release