



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

**Divisions**  
Accounting  
Communications & Education  
Customer Service  
Engineering & Records  
Stormwater Management  
System Maintenance  
Water Protection

## Press Release

## Information on Sewer Overflow

Cobb County, GA - Mar 8, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: March 5, 2021  
Location of overflow: 391 DONFRED DR SW, MABLETON, GA 30126  
This overflow resulted from: ROOTS  
Resulting in a wastewater discharge into: TRIBUTARY TO QUEEN CREEK  
The volume of the overflow was estimated at: 360 Gallons  
The Water System was notified at: Mar 5, 2021, 10:58 AM  
The overflow was stopped at: Mar 5, 2021, 2:00 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to clear blockage and sprayed enzyme on spill area.

Field Observation:

Upon arrival, crew found sewage coming from the ground, leaving a light gray 2' x 100' trail inside the storm drain ditch. Sewage left liquid only, no debris.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**