



## COBB COUNTY WATER SYSTEM

### System Maintenance Division

680 South Cobb Drive  
Marietta, GA 30060-3114  
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions  
Accounting  
Communications & Education  
Customer Service  
Engineering & Records  
Stormwater Management  
System Maintenance  
Water Protection

## Press Release

## Information on Sewer Overflow

Cobb County, GA - May 10, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: May 8, 2021  
Location of overflow: 1220 BUCKNER RD, MABLETON, GA 30126  
This overflow resulted from: GRAVEL  
Resulting in a wastewater discharge into: TRIBUTARY TO NICKAJACK CREEK  
The volume of the overflow was estimated at: 190 Gallons  
The Water System was notified at: May 8, 2021, 3:30 PM  
The overflow was stopped at: May 8, 2021, 5:05 PM

Corrective action taken to reduce effects of the overflow include the following:

Used jet machine to clear blockage from the mainline. Cleaned the affected area and applied lime.

Field Observation:

Upon arrival, crew found manhole #214-H054 spilling with lid in place. Sewage left a 5' x 10' gray area on the banks of the creek.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

**For Immediate Release**