



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Sep 10, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: September 9, 2021
Location of overflow: 294 INTERSTATE NORTH CIR, ATLANTA, GA 30339
This overflow resulted from: STRUCTURAL
Resulting in a wastewater discharge into: ROTTENWOOD CREEK
The volume of the overflow was estimated at: 4170 Gallons
The Water System was notified at: Sep 9, 2021, 5:45 PM
The overflow was stopped at: Sep 10, 2021, 3:40 AM

Corrective action taken to reduce effects of the overflow include the following:

Crew installed a bypass pump to stop the spill. The crew then reconnected the 10" steel pipe into manhole #134-9197 and sealed the manhole.

Field Observation:

Upon arrival, crew found manhole #134-9197 overflowing and sewage spilling into water way. Sewage ran down hill about 30' and entered Rottenwood Creek.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release