



COBB COUNTY WATER SYSTEM

System Maintenance Division

680 South Cobb Drive
Marietta, GA 30060-3114
Phone: (770) 419-6351

Judy B. Jones, P.E. - Director

Divisions
Accounting
Communications & Education
Customer Service
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Press Release

Information on Sewer Overflow

Cobb County, GA - Nov 12, 2021

Pursuant to the rules and Regulations for Water Quality Control, Chapter 391-3-6-05, the Georgia Environmental Protection Division now requires all publicly owned wastewater treatment works that discharge to the waters of the State to provide information on sewer overflows to local media contacts as part of ongoing, comprehensive public education and awareness efforts.

A wastewater overflow occurred on: November 10, 2021
Location of overflow: 3844 LAUREL DR ACWORTH, GA 30101
This overflow resulted from: GREASE
Resulting in a wastewater discharge into: TRIBUTARY TO BUTLER CREEK
The volume of the overflow was estimated at: 400 Gallons
The Water System was notified at: Nov 10, 2021, 4:35 PM
The overflow was stopped at: Nov 10, 2021, 7:55 PM

Corrective action taken to reduce effects of the overflow include the following:

Unstopped from manhole #500-A029A with jet machine to clear grease from line. Cleaned area with lime.

Field Observation:

Upon arrival, crew checked manholes in area and observed manhole #500-A060 discharging sewage with lid in place. Sewage left 4" by 4" gray stained patch leading to waterway.

For more information on this notification, contact our System Maintenance Division Monday - Friday, 7:00 a.m. to 3:30 p.m. at 770-419-6351.

###

For Immediate Release