

Work Group	WO Number	Description	Problem Type	Work Date	Status	Status Date
WSSTANDB	3154121	INSTALL METER	NOWATER	26-Nov-21	DONE	11/26/2021 5:55:40 PM
WSSTANDB	3154126	LOW PRESSURE	LOWPRESSURE	26-Nov-21	DONE	11/26/2021 8:08:29 PM
WSSTANDB	3156025	SEWER BACKUP	BLOCKAGE	27-Nov-21	DONE	11/27/2021 8:05:40 PM
WSSTANDB	3157911	SEWER BACK UP	BLOCKAGE	28-Nov-21	DONE	11/28/2021 12:18:48 PM
WSSTANDB	3157912	SEWER BACK UP	BLOCKAGE	28-Nov-21	DONE	11/28/2021 4:30:07 PM
WSSTANDB	5					
WSSWING	3150378	DISCOLORED-BAD TASTE	WATERQUALITY	24-Nov-21	DONE	11/25/2021 2:04:50 AM
WSSWING	3159878	Discolored Water	WATERQUALITY	29-Nov-21	DONE	11/29/2021 9:21:04 PM
WSSWING	2					
WSZONE1	1864891	Dig Up - repair 8 inch clay main on golf course	BROKEN	30-Nov-21	DONE	11/30/2021 2:42:11 PM
WSZONE1	3140810	LOCATE/ INSTALL TAP FEES PD	LOCATETAP	24-Nov-21	REVIEW	11/24/2021 8:45:10 AM
WSZONE1	3144629	Flush Water Main @ Woodcreek Way off of Woodstock Rd. (Back of Neighborhood)	WATERQUALITY	24-Nov-21	DONE	11/24/2021 10:11:08 AM
WSZONE1	3150366	SEWER ODOR	ODOR	24-Nov-21	DONE	11/24/2021 2:22:46 PM
WSZONE1	3159851	SEWER BACK UP	SSOVERFLOW	29-Nov-21	DONE	11/29/2021 3:32:26 PM
WSZONE1	5					

WSZONE2	3121280	Dig Up - Separation at connection on county rt of way3ft from clean out.	BROKEN	24-Nov-21	DONE	11/24/2021	12:30:25 PM
WSZONE2	3150373	MANHOLE COVER LOOSE	MANHOLELID	24-Nov-21	DONE	11/30/2021	11:37:33 AM
WSZONE2	3159857	LOCATE FOR SEWER TAP	LOCATETAP	29-Nov-21	DONE	11/29/2021	2:41:40 PM
WSZONE2	3161788	Manhole Holding	BLOCKAGE	30-Nov-21	DONE	11/30/2021	5:39:31 PM

WSZONE2 4

WSZONE3	3064360	Landscape Type SOD - 13x8 1940 Leland dr Wood chips 1885 Leland dr	LANDSCAPE	30-Nov-21	DONE	11/30/2021	11:45:21 AM
WSZONE3	3138892	Landscape Type MULCH - 4 bag brown	LANDSCAPE	30-Nov-21	DONE	11/30/2021	9:55:10 AM
WSZONE3	3146478	locate valve V161184030 and adjust box	VALVENOTACCESS	30-Nov-21	DONE	11/30/2021	11:36:13 AM
WSZONE3	3146482	check for sewer availability in area. check with 2430	SURVEY	29-Nov-21	DONE	11/30/2021	2:43:50 PM
WSZONE3	3148361	check report of exposed s/s main in creek	EXPOSED	24-Nov-21	DONE	11/24/2021	10:53:29 AM
WSZONE3	3150365	locate and raise valve # V170876009	LOCATEVALVE	24-Nov-21	DONE	11/25/2021	11:48:20 AM
WSZONE3	3157917	Flush Sewer Main 123-9001 to 123-0005A @ 5076 Nifda Dr	PREVENT	29-Nov-21	DONE	11/29/2021	9:43:14 AM
WSZONE3	3157920	Check Pressure on Hydrant @ 4641 Woodland Brook Dr	PUNCHLIST	29-Nov-21	DONE	11/29/2021	11:55:21 AM
WSZONE3	3161752	check manholes in area for hydrogen sulfide damage	ADJUSTMENT	30-Nov-21	DONE	11/30/2021	4:01:54 PM

WSZONE3 9

WSZONE4	3052221	Landscape Type SEED AND HAY -	LANDSCAPE	29-Nov-21	DONE	11/29/2021	8:42:58 AM
WSZONE4	3135099	Landscape Type SEED - Seed and hay. Pine straw.	LANDSCAPE	29-Nov-21	DONE	11/29/2021	12:23:32 PM
WSZONE4	3138929	Landscape Type SEED -	LANDSCAPE	29-Nov-21	DONE	11/29/2021	3:12:18 PM

WSZONE4	3146505	CCTV - camera main between manhole #308-9161--308-9160B	SURVEY	29-Nov-21	DONE	11/29/2021	11:03:23 AM
WSZONE4	3159847	SEWER BACK UP	BLOCKAGE	29-Nov-21	DONE	11/29/2021	12:28:45 PM
WSZONE4	3161774	SEWER BACK UP	BROKEN	30-Nov-21	DONE	11/30/2021	3:29:25 PM

WSZONE4 6