

8/12/2026

TO: HOLDERS LIST

SUBJECT: Aluminum Gangway
ITB NO. 072026-1046

ADDENDUM NUMBER # 01

This addendum is issued to update the design live load criteria from 100 PSF to 50 PSF for the Aluminum Gangway and extend the bid submittal deadline listed on Page 1 and 10 and Attachment A of the ITB:

Page 1:

Bid Submittal Deadline **AUGUST 19, 2026 @ 2:00 PM (PST)**

Attachment A - Page 10:

SOLICITATION TIMELINE:

Issuance of Solicitation	JULY 16, 2026
Last Day to Submit Questions	AUGUST 6, 2026 @ 2:00 PM (PST)
Bid Packets Due	AUGUST 19, 2026 @ 2:00 PM (PST)
Review/Shortlist*	AUGUST 20, 2026
Interviews (if required)*	N/A
Final Selection*	AUGUST 21, 2026
Execute Contract*	AUGUST 28, 2026

Attachment D - Drawing S1, Design Criteria:

2. LIVE LOADS - ~~UNIFORM 100 PSF~~ 50 PSF

The revised 50 PSF live load is intended for personnel and small tools/equipment only.

All other terms, conditions, specifications, and requirements remain unchanged.

**Aluminum Gangway
ITB NO. 072026-1046**