QUESTIONS & RESPONSES #01

PROCUREMENT NUMBER: 012026-1014
RFP/RFQ TITLE: West Sitcum 11th St. Improvements
CONTACT: Michelle Walker, Procurement Analyst
EMAIL: procurement@portoftacoma.com
PHONE NUMBER: 253-888-4744
QUESTIONS DUE DATE: Tuesday, May 26, 2026 @ 2:00 PM (PDT)
Q&A ISSUE DATE: 05/22/26

#	Question	Answer	Question #
1	Do the Contract Documents allow for the reuse of excavated on-site materials?	Yes. The Contract Documents allow for the reuse of excavated on-site materials where such materials meet the requirements of Section 31 23 33 – Trenching & Backfilling. The Port shall evaluate excavated materials and may process and allow for the reuse materials that conform to the specified CSBC requirements, subject to acceptance. A bid item for Crushed Surfacing Base Course (CSBC) is included to establish unit pricing in cases where imported material is required due to unsuitable or contaminated conditions. Bids shall be based on the Contract Documents.	Received at Site Visit