

**QUESTIONS & RESPONSES #02**

**PROCUREMENT NUMBER: 012026-1014**

**RFP/RFQ TITLE: West Sitcum 11th St. Improvements**

**CONTACT: Michelle Walker, Procurement Analyst**

**EMAIL: [procurement@portoftacoma.com](mailto:procurement@portoftacoma.com)**

**PHONE NUMBER: 253-888-4744**

**QUESTIONS DUE DATE: Tuesday, May 26, 2026 @ 2:00 PM (PDT)**

**Q&A ISSUE DATE: 05/28/2026**

#	Question	Answer	Question #
1	Do the Contract Documents allow for the reuse of excavated on-site materials?	Yes. The Contract Documents allow for the reuse of excavated on-site materials where such materials meet the requirements of Section 31 23 33 – Trenching & Backfilling. The Port shall evaluate excavated materials and may process and allow for the reuse materials that conform to the specified CSBC requirements, subject to acceptance. A bid item for Crushed Surfacing Base Course (CSBC) is included to establish unit pricing in cases where imported material is required due to unsuitable or contaminated conditions. Bids shall be based on the Contract Documents.	Received at Site Visit
2	Detail 1/C1.0 on plan sheet 8 of 15 shows 8" of compacted CSTC and 4" of HMA. Can you add a bid item for the CSTC?	The detail will be revised to replace CSTC with CSBC for consistency. The added bid item for CSBC will apply; no separate CSTC bid item will be added.	Q-003876
3	Is the port providing compaction testing or does the contractor need to pay for testing?	The port will provide and pay for all required on-site testing and inspection services, including compaction testing, in accordance with Sections 01 45 00, 31 00 00 (3.08A), 31 23 33 (1.02A), 32 11 23 (1.03B).	Q-003876