

QUESTIONS & RESPONSES #03

PROCUREMENT NUMBER: 012026-1014

RFP/RFQ TITLE: West Sitcum 11th St. Improvements

CONTACT: Michelle Walker, Procurement Analyst

EMAIL: procurement@portoftacoma.com

PHONE NUMBER: 253-888-4744

QUESTIONS DUE DATE: Tuesday, May 26, 2026 @ 2:00 PM (PDT)

Q&A ISSUE DATE: 06/04/2026

#	Question	Answer	Question #
1	Do the Contract Documents allow for the reuse of excavated on-site materials?	Yes. The Contract Documents allow for the reuse of excavated on-site materials where such materials meet the requirements of Section 31 23 33 – Trenching & Backfilling. The Port shall evaluate excavated materials and may process and allow for the reuse materials that conform to the specified CSBC requirements, subject to acceptance. A bid item for Crushed Surfacing Base Course (CSBC) is included to establish unit pricing in cases where imported material is required due to unsuitable or contaminated conditions. Bids shall be based on the Contract Documents.	Received at Site Visit
2	Detail 1/C1.0 on plan sheet 8 of 15 shows 8" of compacted CSTC and 4" of HMA. Can you add a bid item for the CSTC?	The detail will be revised to replace CSTC with CSBC for consistency. The added bid item for CSBC will apply; no separate CSTC bid item will be added.	Q-003876
3	Is the port providing compaction testing or does the contractor need to pay for testing?	The port will provide and pay for all required on-site testing and inspection services, including compaction testing, in accordance with Sections 01 45 00, 31 00 00 (3.08A), 31 23 33 (1.02A), 32 11 23 (1.03B).	Q-003876
4	The drawings and specs do not call out a size for the handholes shown on the electrical drawings. What size should the handholes be?	Handhole size is not specifically defined in the Contract Documents. Contractors shall submit product data for handholes in accordance with Section 26 05 43 (including Submittals and product requirements). Handholes shall be sized by the Contractor to accommodate the conduit and cable configuration shown in the drawings and to meet all applicable requirements of the contract documents.	Email