

October 28, 2026

TO: PLANHOLDERS

SUBJECT: SKID MOUNTED MOBILE SHORE POWER CABLE REEL
PROCUREMENT NO. 092026-1057

ADDENDUM NUMBER 01

This addendum is issued to amend the following:

SPECIFICATIONS.

- A. In Section **C. SPECIFICATIONS**, under the invitation to bid specifications, a sentence under **Warranty Services and Performance** is Revised to read - The warranty period shall be a minimum of ~~five (5) years~~ **one (1) year** and shall commence on the earlier of: (a) the date the equipment is placed into service by NWSA; or (b) thirty (30) days after final payment.
- B. **Attachment C** – Paragraph 1.9 A, is **Revised** to read - Provide Supplier/Manufacturer's standard warranty, but not less than ~~Five (5) years~~ **one (1) year** from commence on the earlier of: (a) the date the equipment is placed into service by NWSA; or (b) thirty (30) days after final payment, covering the complete integrated electrical assembly, structural elements, cables, connectors, controls, interlocks, reel drive, collectors, and workmanship.
- C. **Attachment C** – Paragraph 2.5 E6 Communications is **Revised** to read - Provide shielded communications conductors required to reproduce all existing shore power communications and permissive functions through the extension assembly. Quantity, type, optical characteristics, shielding, and connectorization shall match the existing system, with spare capacity not less than that present in the existing fixed connection. **See also Paragraph 2.11 for communications and pilot circuit requirements.**
- D. **Attachment C** – Paragraph 2.11 B, is **Revised** to read- Maintain circuit isolation, shielding, grounding, polarity, ~~fiber type~~, optical performance, and pin assignments required by the existing Port system.
- E. **Attachment C** – Paragraph 2.11 C is **Revised** to read - Provide accessible termination or junction provisions for testing and replacement. Identify all conductors, ~~fibers~~, connectors, and terminals at both ends and at intermediate junction points.
- F. **Attachment C** – Paragraph 2.11 D. ~~Fiber optic connections shall be protected from contamination and mechanical damage. Provide dust caps and manufacturer approved cleaning provisions.~~ is **Deleted**
- G. **Attachment C** – Paragraph 2.12 A is **Revised** to read – Provide powered reel-in and reel-out operation sized for the two cable assemblies under all specified operating conditions. **Either reel drive and control or similar hydraulic unit operation are acceptable.**

- H. **Attachment C** – Paragraph 2.12 B is **Revised** to read - Provide adjustable speed and torque control using a variable-frequency drive or equivalent ~~controlled-drive~~ **control** system. Tune the drive / **system** to deploy and retrieve cable without exceeding allowable pulling tension.
- I. **Attachment C** – Section 2.14 **Add** the following paragraph.
- F. **If a hydraulic power unit is used for reel operations, all hydraulic components shall be compatible for use in salt-water marine environments.**

DRAWINGS

1. None.

ATTACHMENTS

1. None.

END OF SECTION