



## QUESTIONS & RESPONSES 01

RFQ or RFP / TITLE **070444 - 2017 APMT Fender Repair**

CONTACT **Steve Johnson, Procurement**

EMAIL **[procurement@portoftacoma.com](mailto:procurement@portoftacoma.com)**

PHONE NUMBER **253-592-6207**

BID DUE DATE **June 20, 2017 @ 2:00 PM (PST)**

DATE ISSUED **May 30, 2017**

PROPOSER QUESTIONS	PORT RESPONSES
What is the rate we would have to pay for security on days no security guard is present (both weekday/weekend rate)?	Gate costs are \$68.22 per hour with a 4 hour minimum.
If start of work gets hung up waiting on TWIC card/clearance, will owner grant additional contract time accordingly?	No.
Piledriving specs reference the use of fixed leads for all piledriving activities. Please confirm this will not be required for vibratory driving.	The use of fixed leads for vibratory installation of the fender piles is not required provided sufficient templates or other means/methods are utilized to meet the required installation tolerances.
Can you provide any geotech information for the project site?	No.
Plan sheet S3.0, Detail A, Shows UHMW Pile Protection Panels on new piles. How is that panel attached to the pile?	Reference sheets S3.1, S4.0 and S4.1.