



QUESTIONS & RESPONSES #01

RFP or RFQ / TITLE 071255 |PCT MARINE BUILDING STAIRWAY
CONTACT Heather Shadko, PROCUREMENT
EMAIL procurement@portoftacoma.com
PHONE NUMBER 253-428-8697
SUBMITTAL DUE DATE June 16, 2020 @ 2:00 PM (PST)
Q&A ISSUE DATE June 5, 2020

PROPOSER QUESTIONS	PORT RESPONSES	RFP/ RFQ Section
Regarding the PCT Stairs Bid, is there no paint system applied in this bid?	All steel items shall be hot-dip galvanized and coated per Structural Steel Note #10 on Dwg No. S1, and in accordance with the requirements of Section 05 50 00 Metal Fabrications and Section 09 96 00 High Performance Coatings.	05 50 00